

SINGLE-SECTION INSULATED LADDER

Reference	Standard	Decree	
04310108	EN 131	96-333	3178740185640
04310110	EN 131	96-333	3178740185657
04310112	EN 131	96-333	3178740185664
04310114	EN 131	96-333	3178740185671
04310117	EN 131	96-333	3178740185688



Compliant with the following information

Class	Professional
Standard requirements	Electrical test in compliance with EN 50528 (2010)
Maximum load (kg)	150
Recyclable up to (%)	26

The EN 50528 (2010) standard sets out the values that guarantee users against low-voltage currents under 1000 volts AC or 1500 volts DC. The breakdown test is 10,000 volts.
 Producentforakrften Certificate C901062. AFS 2004:3 Certificate C901061. SS 2091 edition 4 Certificate C901061. Tested and certified by RISE.

We certify that the product has been made according to technical specifications of the market and customer's order. All control operations and tests have been carried out. The product complies with all aspects of the attached specifications, drawings and current standards and regulations.



Models shown: 04310108 / 04310112

Supplier control

DELOGE Virginie - Quality manager

TUBESCA-COMABI

SAS au capital de 6 393 200 Euros
SIREN 422 481 838

976, Route de Saint Bernard - BP 414
01604 TREVOUX Cedex
Tél.: 04 74 00 90 90